

99 South Bedford St.

AMRI – Special Permit Application

Section 4.2.7.11

REASON: Replacement of existing emergency generator with on board 320 gallon diesel fuel storage tank with new larger generator that will have larger on board storage tank of 660 gallons of diesel fuel.

PURPOSE: AMRI drug manufacturing operations require uninterrupted power supply. They use a backup generator to meet that requirement. Food & Drug Administration requires that the ingredient materials and end product be maintained at certain temperature range throughout the manufacturing process, storage, transportation and end user storage up to point of patient use. At any given time during manufacture and storage within AMRI's 99 South Bedford St. location the value of those materials and end product is +/- \$1.0 million. AMRI loss control protocols and insurers covering product loss of these materials and end product also require the uninterrupted power supply by way of emergency generation power plant.

**Mark W. Gemmiti**

*Sr. Project Superintendent*

*MA Lic. #CS-106020*



**IPS-Integrated Project Services, LLC**

100 Apollo Drive | Suite 105 | Chelmsford, MA 01824

P 978.954.5450 | C 603.673.1828

[email](#) • [website](#) • [linkedin](#) • [facebook](#) • [twitter](#)